

New Filtration Process (200 litres)					
Number of passes	Filter Change	Water Content mg/kg	Breakdown kV	Acid	IFT
Start		4042	6		
2		729			
4		370			
6		377			
8	yes	350			
10		103			
12		59	22.7		
14	yes	49			
16		44			
18		49	23	0.05	27
20	yes(heated)				
22		45			
24		35			
26		42			
28		41			
30	yes(heated)	34	57	0.05	28.8
32		63			
33	yes(heated)	44			
34		58			

Water Content IEC 60814
 Breakdown IEC 60156
 Acidity IEC 60296
 Interfacial Tension ISO 6295
 NATA 11448

